




TECHNICAL SPECIFICATION

Power Supply	100 to 240 VAC 50/60 Hz
Power Consumption	24 VAC/VDC ±15%
Measurement Range	0 to 80°C ±2°C
Output	Contact 2A 250VAC, 2A 30VDC
Alarm Output	Contact 2A 250VAC, 2A 30VDC
Display	7 Segment 3 Digit, 1 Row
Function Control	Heat/Coll, ON/OFF Control
Temperature Operating	0-80°C
Humidity Operating	0-75 %RH
Size	40 x 90 x 62 mm
Weight	114.8g

DIMENSION CUTTING AND INSTALLATION




DESCRIPTION

- CMA-002 is digital temperature controller device inside cabinet
- Display number by 7-Segment 3 digits 1 row.
- Command ON/OFF fan for exchange heat inside electrical or control cabinet.
in case temperature that measure over than setpoint value CMA-002 will command fan to turn on for cooling. Saving electrical and extend the service life of the fan
- Probe inside device.
- 1 Relay Output and 1 Alarm Relay Output.
- Alarm Output use in case Relay Output operate then cannot made temperature as required it will has Alarm Output is notification.
- Can set ON point and OFF point of Relay independently.
- Delay Rime delay before Relay Output operate 0-999 Sec.
- ON/OFF operation function choose controlling in both Heat/Cool.


OPERATION

CMA-002 is ON/OFF temperature controller device can choose how to control in 2 way are heat or cool by CMA-002 has temperature sensor inside so no need to connect external sensor has 1 Relay Output and 1 Alarm Relay Output for Alarm display by 3 digits 7-Segment.

WIRING DIAGRAM





OPERATION SETTING



Cool Function : Input analog to be used as Output Relay.

Heat Function : Input analog to be used as Output Relay.




Cool Function Control Calculation
ON Temp = Set Point + OFF Value + ON Value
OFF Temp = Set Point + OFF Value

Heat Function Control Calculation
ON Temp = Set Point + OFF Value - ON Value
OFF Temp = Set Point + OFF Value

ALARM OUTPUT

Input analog to be used as Alarm Output, PV abnormal : Input indicates "Over" or "Under", alarm output turn on.
Stand-by sequence : After starting operation of step, alarm output does not turn on unless the power on alarm override value is clear or defrost alarm override value is clear




Alarm output Activation : After Power on, alarm output does not turn on unless input value is maintaining between Alarm high check and Alarm low check

Calculate Alarm check for Deviation
Alarm high check = SP+HAL-ADF
Alarm low check = SP-LAL+ADF
Calculate Alarm limited for Deviation
Alarm high check = SP+HAL
Alarm low check = SP-LAL

Calculate Alarm check for Absolute
Alarm high check = HAL-ADF
Alarm low check = LAL+ADF
Calculate Alarm limited for Absolute
Alarm high check = HAL
Alarm low check = LAL


Example 1 CON=1 (Heat Function) SP = 40, ON = 1, และ OFF=0

ตั้งน้้นจากสูตร ON temp = 40+0-1 = 39 และ OFF Temp = 40+0 = 40




Example 2 CON=0 (Cool Function) SP = 35, ON = 5, และ OFF=0

ตั้งน้้นจากสูตร ON temp = 35+0+5 = 40 และ OFF Temp = 35+0 = 35




Example 3 TAL = 2 (Deviation low alarm limit) SP = 40, ADF = 5, และ LAL=5

ตั้งน้้นจากสูตร Alarm low check = 40-5+5 = 40 และ Alarm low limite = 40-5 = 35




Example 4 TAL = 5 (Absolute low alarm limit) SP = 40, ADF = 5, และ LAL=35

ตั้งน้้นจากสูตร Alarm low check = 35+5 = 40 และ Alarm low limite = 35




Example 5 TAL = 5 (Absolute low alarm limit) SP = 40, ADF = -5, และ LAL=40

ตั้งน้้นจากสูตร Alarm low check = 40+(-5) = 35 และ Alarm low limite = 40




Example 6 TAL =1 (Deviation high alarm limit) SP = 40, ADF = 5, และ HAL=5

ตั้งน้้นจากสูตร Alarm high check = 40+5-5 = 40 และ Alarm lhigh limite = 40+5 = 45




Example 7 TAL = 4 (Absolute high alarm limit) SP = 40, ADF = 5, และ HAL=40

ตั้งน้้นจากสูตร Alarm high check = 40-5 = 35 และ Alarm High limite = 40



Example 8 TAL = 4 (Absolute high alarm limit) SP = 40, ADF = -5, และ HAL=40


ตั้งน้้นจากสูตร Alarm high check = 40-(-5) = 45 และ Alarm High limite = 40



Example 9 TAL =3 (Deviation high and low alarm limit) SP = 40, ADF = 5, และ HAL=10

ตั้งน้้นจากสูตร Alarm high check = 40+10-5 = 45 และ Alarm lhigh limite = 40+10 = 50

จาก LAL=10 ได้ Alarm low check = 40-10+5 = 35 และ Alarm low limite = 40-10 = 30



ORDERING CODE

CMA-002-	
NONE	100 - 240 VAC 50/60 Hz
24	24 VAC/VDC ±15%



บริษัท ไพรมัส จำกัด
119 ซ.สีม่วงอนุสรณ์ ถ.สุทธิสารวินิจฉัย แขวงดินแดง
เขตดินแดง กรุงเทพฯ 10400
โทร 0-2693-7005, 0-2277-8027 แฟกซ์ 0-2277-3565
E-mail : sales@primusthai.com